

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0003		3. EFFECTIVE DATE 09/18/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 08-0094	
6. ISSUED BY CODE		CODE	7. ADMINISTERED BY (If other than Item 6) CODE		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		mks	See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO.
				X	N40085-08-R-0094
					9B. DATED (SEE ITEM 11) 09/04/09
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

08-0094, ARRA, AS705 Renovation

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Question: Hardware set 14 is listed with roller latches and an F36 preassemble passage set (2000 series lock). This will not work with the roller latches. I think what they meant to have here is 4000 series dummy levers. Please confirm.  
1. RESPONSE- Agree, use 4000 series dummy levers
  
2. Question: Hardware set 10 lists an F41 function lockset which is also a 2000 series lock, but the specs call for 4000 series. I think you need an F82 lock. Please confirm.  
2. RESPONSE- Agree that lock should be F82
  
3. Question: Hardware set 15 lists an F36 function lockset which is also a 2000 series lock, but the specs call for 4000 series. I think you need an F75 lock. Please confirm.  
3. RESPONSE- Agree that lock should be F75
  
4. Question: Please verify doors 1106A and 1106B are hollow metal b/c they are given hardware set 5, and hardware set 5 says exterior storefront.  
4. RESPONSE- Doors 1106A and 1106B are hollow metal doors. Use hardware set as follows:  
1-1/2 hinges A5111x630  
1 ea mortise lockset w/access card xF08  
1 ea O/H closer C02021x689  
1 set weather stripping as specified  
1 set threshold J36130x673x1/2" offset
  
5. Question: Please verify that returns are necessary at the hollow metal frames at masonry openings. They are not needed at masonry openings.  
5. RESPONSE- Returns are not necessary at masonry openings
  
6. Question: Heavy weight hinges are shown in every hardware set. Please verify this is necessary.  
6. RESPONSE-- Heavy weight hinges are only required for exterior doors and common use doors (laundry and toilets). Standard weight hinges are acceptable for toilet doors and closet doors in individual rooms and all doors in area C.

CONTINUATION SHEET

7. Question: At room 1027 on the demo plans it is showing the closets doors, frame, hardware being demolished, but on the door schedule there is no new door/frame/hardware listed for this opening. Please advise.
7. RESPONSE- The door/frame/hardware for door 1027 to be the same as door 1018
8. Question: On the demo sheet AD103 it shows doors/frames/hardware 1107A, 1107B to be demolished complete, but on the door schedule it shows these doors to have an existing frame. Please advise.
8. RESPONSE-- On sheet AD103, demolition note 13 .."existing frame to remain" applies to both doors
9. Question: None of the openings are listed as rated in the door schedule. Please verify this is correct.
9. RESPONSE-- Correct, for code compliance, the doors are required to have a 20 minute fire rating. This is attained with a hollow metal door.
10. Question: In the toilet accessory specification it says to provide mirrors in sizes shown on drawings, but I do not see any sizes shown. Please provide a size for mirrors, tilt mirrors and medicine cabinets.
10. RESPONSE-- mirrors to be framed 18"x30", tilt mirrors to be 24"x36", and medicine cabinets to be 17"x26" with four adjustable shelves.