

| | | | | |
|--|--|-----------------------------------|---|---|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | 1. CONTRACT ID CODE | PAGE OF PAGES 1 2 |
| 2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0001 | | 3. EFFECTIVE DATE Feb 25, 2010 | 4. REQUISITION/PURCHASE REQ. NO. | 5. PROJECT NO. (If applicable) 09-0042 |
| 6. ISSUED BY CODE | | sta | 7. ADMINISTERED BY (If other than Item 6) CODE | |
| Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521 | | | See Item 6 | |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) | | | 9A. AMENDMENT OF SOLICITATION NO. <input checked="" type="checkbox"/> N40085-09-R-0042 | |
| | | | 9B. DATED (SEE ITEM 11) Feb 19, 2010 | |
| | | | 10A. MODIFICATION OF CONTRACT/ORDER NO. | |
| | | | 10B. DATED (SEE ITEM 13) | |
| CODE | | FACILITY CODE | | |

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

| | | |
|--------------------------|---|---|
| CHECK ONE | A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) NO. IN ITEM 10A. | THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER |
| <input type="checkbox"/> | B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). | |
| <input type="checkbox"/> | C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: | |
| <input type="checkbox"/> | D. OTHER (Specify type of modification and authority) | |

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

09-0042 ADD STORAGE AND HEADS TO BUILDING BB-6

CLARIFICATION TO BIDDERS INQUIRES

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

| | | | |
|---|--|--|--|
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | |
| 15B. CONTRACTOR/OFFEROR | | 16B. UNITED STATES OF AMERICA | |
| 15C. DATE SIGNED | | 16C. DATE SIGNED | |
| (Signature of person authorized to sign) | | (Signature of Contracting Officer) | |

SUMMARY OF CHANGES:

ADD STORAGE AND HEADS TO BUILDING BB-6 – INCORPORATE INTO THE SOLICITATION THE ITEMS LISTED BELOW:

QUESTION 1: Sheet P-2 describes a regular style water closet and specifications describe both standard and handicap. There is not any handicap toilet compartments shown on the architectural drawings. Should we only provide standard height water closets?

ANSWER: Building BB-6 is for able bodied personnel. Provide standard water closet as scheduled on Sheet P-2.

QUESTION 2: Plumbing Fixture Schedule on sheet P-2 describes only the shower valve and the shower drain (P-5 and SFD) Plumbing Specifications describe a Plastic Shower Enclosure. Sheet P-2, fixtures described, suggest a ceramic tile shower enclosure but the finish schedule (Sheet A-3) says that the walls are 5/8" moisture resistant gypsum board. Which is required?

ANSWER: Reference Sheet P-2 Plumbing Fixture Schedule, item P-5 Shower, provide 36x36 private enclosure with wall mounted chrome plated mixing valve, lo-flo shower head, include shower floor drain as scheduled. Building BB-6 is for able bodied personnel and an ADA compliant shower is not required.

QUESTION 3: Plumbing Fixture Schedule Sheet P-2, Fixture P-4 calls for Enameled cast iron lavatory and plumbing specs call for vitreous china. Which is required?

ANSWER: Lavatory Fixture P-4 shall be enameled cast iron.