

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0001	3. EFFECTIVE DATE Feb 10, 2010	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-0149	
6. ISSUED BY CODE	sta	7. ADMINISTERED BY (If other than Item 6)		CODE
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0149
			<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) Feb 4, 2010
				10A. MODIFICATION OF CONTRACT/ORDER NO.
			<input type="checkbox"/>	10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

09-0149 REPAIR APPLIED INSTRUCTION, BUILDING BB48

The Bid Opening is hereby changed from 17 February 2010 @ 1:00 PM to 24 February 2010 @ 1:00 PM

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA
(Signature of person authorized to sign)			(Signature of Contracting Officer)
			16C. DATE SIGNED

SUMMARY OF CHANGES:

ADD the following:

REPAIR APPLIED INSTRUCTION BUILDING, BB48 - INCORPORATE INTO THE SOLICITATION THE ITEMS LISTED BELOW:

- 1) At location indicated, provide:
  - a) 6" thick concrete slab, 6'x8'. Locate any utilities in the area surrounding LP tank site and proposed location of gas line.
  - b) 3/8" copper or 1/2" polyethylene underground gas line from slab to building. Saw cut and patch asphalt to match existing. Gas line shall stub up through oversized sleeve in slab, 3" from edge.
  - c) 1st stage regulator for 10 psig.
  - d) (4) Protective bollards, one at each corner, each bollard to be 7' long, 4" schedule 40 galvanized steel, concrete filled, 3' bury with concrete encased, paint bright yellow/black with 4" stripes.
  - e) Make tank hook up.
  - f) Sufficient gas for start up, and construction period until BOD.
- 2) Provide second stage regulator to reduce pressure to burner pressure, locate on outside of building at location shown as entrance point on sheet M1.1. Provide building shut off valve.
- 3) On sheet M1.1, delete reference and requirement for 2# to 14" regulator located inside building near IRH-1.
- 4) On sheet M1.1, provide schedule 40 black steel pipe for interior propane gas pipe.

5) Contractor shall provide two 8" x 20" lockable containers on site for the duration of the construction contract.

