

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>	1. CONTRACT ID CODE	PAGE OF PAGES 1 2
---	---------------------	----------------------

2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002	3. EFFECTIVE DATE 08/14/08	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 08-0085
---	-------------------------------	----------------------------------	---

6. ISSUED BY CODE  Resident Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521	7. ADMINISTERED BY (If other than Item 6) CODE  See Item 6
--	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-08-R-0085
	x	9B. DATED (SEE ITEM 11) 08/07/08
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
(a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

08-0085, Installation of E85 Tank

CONTINUED

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	16B. UNITED STATES OF AMERICA  (Signature of Contracting Officer)
15C. DATE SIGNED	16C. DATE SIGNED

## CONTINUATION SHEET

1. Question: Specifications call for cylindrical primary tank and rectangular secondary tank which not available. Is both being cylindrical horizontal UL 2085 acceptable at a significant cost savings, or should we bid on both primary and secondary being rectangular?

Answer: Yes, as long as the tank is compliant with the NFPA 30, UL 2085 and UL142.
  
2. Question: Specifications call for Stage II Vapor Recovery in accordance with the State of NC. NC does not require this for this location, and Stage II requirements will be eliminated for all counties shortly. Is this going to be a requirement?

Answer: Stage II Vapor Recovery shall be included, the pipe for the Stage II Vapor Recovery shall be capped in the dispenser sump.
  
3. Question: The dispensers are specified to show dollars similar to a service station, and are to have pumps internally. Typically in this application we use commercial electronic remote dispensers showing gallons only.

Answer: Specification Section 23 12 16.00 20, Paragraph 2.5.1.a, delete/omit "five digit cash display to \$999.99, with automatic shutdown , and."  
Specification Section 23 12 16.00 20, Paragraph 2.5.1.c, delete/omit.  
Specification Section 23 12 16.00 20, Paragraph 2.5.1.e, delete/omit "Sales display shall remain visible for 15 minutes after power failure."
  
4. Question: Specifications call for Management Control System (section 23 12 16.00 20 paragraph 2.5.2). This sounds like a console in a convenience store. Is this correct?

Answer: Delete/Omit Specification Section 23 12 16.00 20, Paragraph 2.5.2.  
Refer to Paragraph 2.7, Fuel Management System, provide a key operated pump similar to existing at the Camp Geiger Fuel Farm; however, suitable for E-85 fuel.
  
5. Question: Can the Project Superintendent, QC Manager and SSHO be the same person for this project?

Answer: Yes, provide level 2 SSHO to meet qualifications.