

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0006		3. EFFECTIVE DATE 02/16/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-0068	
6. ISSUED BY CODE		raa	7. ADMINISTERED BY (If other than Item 6) CODE		See Item 6
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0068
				x	9B. DATED (SEE ITEM 11) 01/25/10
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE				

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

09-0068, Interior & Exterior Repairs, HP-105

1. The date and time for the receipt of proposals are hereby extended to Thursday, 18 February 2010, at 1400.

SEE CONTINUATION SHEET

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

**CONTINUATION SHEET**

2. The answer to Question #4 on Amendment 0004 is hereby changed to the following:

“Preserve and protect all the telecommunications cable, outlets, and equipment. There is no new telecommunications in this project. Any damage will be the contractor’s responsibility to repair and/or replace.”

3. **Question:** According to the ceramic specs [Section 093000, page 6], PARA. 3.3, the wall tile is required to be installed in accordance with TCA HdBk method W221. Per this method, the wall tile is to be installed on a mud-bed with a metal lath. The tile specified does not have the appropriate mud-set trim available. Additionally, the specs call for an 8x8 tile, but the tile listed in the finish schedule only comes in a 12x12 and 18x18. Past renovations have installed the standard 4x4 wall tile (which comes with the trim tiles required), directly on the existing CMU walls after proper preparation. Please advise if 4x4 wall tile will be acceptable without the metal lathe and mud-bed that is not necessarily required.

**Answer:** The new tile we selected for the color range has corresponding mud cap. Our tile council selection requires a metal lath which is appropriate for new tile over previously removed tiles.

Sheet A-601 on the Color & Material Selection chart replaces the porcelain tile with:

Sleeping room toilet/showers: American Olean Highland Ridge "Desert" HR50 6"x6" through body porcelain wall and floor tile and corresponding 2"x2" mosaic tile for shower floor.

Specification: 09 30 00 - 2.1.2 Porcelain Tile - Change 8"x8" nominal size to 6"x6" nominal size.

Other tile selection:

Daltile - Aspen Lodge, "Morning Breeze" AL60

Marazzi - Walnut Canyon "Cream"