

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0012		3. EFFECTIVE DATE 02/12/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 06-0054	
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-06-R-0054
				X	9B. DATED (SEE ITEM 11) 01/26/10
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE				

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

06-0054, Interior/Exterior Repairs to BEQ HP445

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Q: On Sheet A-102 there are 6 towel bars shown, 4 on the walls and 1 each on both doors. On sheet A-402 there are only 3 towel bars shown, 3 on the walls and none on the back of the doors. How many towel bars should be in each restroom?
1. A: 6 towel bars are required in each toilet room – 4 wall mounted and 2 door mounted.
  
2. Q: Plan sheet ED-101 general note 2 says “all cable TV, intercom, telephone conduit, conductors, and cabinets associated with BEQ rooms to remain in place. Preserve and protect all communications cabling, equipment, and jack set assemblies. General contractor will be responsible for any damage or repairs needed to the communications.” This is very open ended. Please quantify extent of repairs needed in this contract for bidding purposes.
2. A: There is no new telecommunications in this project. Preserve and protect all the telecommunications cable, outlets, and equipment. Any damage will be the contractor’s responsibility to repair/replace.
  
3. Q: Bid Item 2 – work associated with conversion of common area to laundry. \*Does the breaker in panel CP1, which feeds to panel LAU, the feeder and panel LAU need to be included in Bid Item 2 of Bid Item 1?
3. A: Breaker in panel CP1 feeding panel LAU to be coordinated with laundry conversion (Bid Item 2).
  
- 4: Q: Spec Section 22000, para. 2.4.1 calls for a floor mounted bottom outlet water closet. Previous BEQ renovations required back outlet water closets. What will be required for this project?
4. A: Floor mounted back outlet water closets are required for this project.

CONTINUATION SHEET

- 5: Q: Sheet MD-401, demo note #6 says “Remove all dual temperature piping.” Sheet MD-402, demo note #12 says “Remove DTS and DTR piping.” Sheet MH-401, new work note #7 only describes new dual temp piping to be run to new outdoor air units in the attic. Sheet MH-402, new work note #6 says “Insulate DTS and DTR piping over common areas. Piping to be insulated as if in unconditioned space.” Are we to supply and install all new dual temp piping or just to the new outdoor air units and new fan coil unit in the laundry room?
5. A: All new piping is required in the building. DTS and DTR piping over common areas must be insulated to unconditioned space insulation specifications.
6. Q: The spec states that the manual flush valve should rough in no higher than eleven inches above the fixture. However, the existing water supply rough in is located at 24 inches above the fixture. Previous BEQ renovation projects changed the flush valves from what the specs called for to extended flush valves to match existing. Please advise.
6. A: Extend flush valves to match existing.