

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0013		3. EFFECTIVE DATE 02/12/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 06-0054	
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-06-R-0054
				X	9B. DATED (SEE ITEM 11) 01/26/10
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

06-0054, Interior/Exterior Repairs to BEQ HP445

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Q: Sheet A-104 has Keyed Ceiling Notes numbered 1 through 5. The first floor ceiling plan shows a note number 6 through the center of the middle hallway. Please advise that finish.
1. A: Note 6 on A-104 should read: Remove existing gypsum board soffit (7'-6" above finished floor) and framing to accommodate new piping. New acoustic ceiling to be at 8'-0" above finished floor throughout.

2. Q: Several notes on the plans reference Glazed Block on the bottom course of the existing masonry. See 8 / A-402 / A-402 & 15 / A-402 / A-602. See attached digital photograph from an existing room in this building. That area does not show any Glazed Block, the existing is painted block with Vinyl Base. Please confirm the extent of any glazed block and the need to use the Glazed Block in the new work. Also the finish schedule is calling for the base to be the existing Glazed Block.
2. A: There is no existing or new glazed concrete block in this project. Use 4" vinyl wall base.

3. Q: See detail 14 / A-101 / A-402. It references Quarry Tile Floor Finish and Base through the Cloths Folding Table in Laundry # 140. The F6 finish for that room is the Standard Resinous Flooring per the finish schedule. Verify the correct finish.
3. A: There is no new quarry tile for this project. Standard resinous flooring is to be used in the laundry rooms.

4. Q: The Demo notes do not reference to remove the Existing Frames, Doors and Hardware for the Bathroom Doors. The Door Schedule list the frames as EXIST or EXISTING and the Doors as EXT. Verify EXT is Existing. There is hardware specified so we assuming the Existing frames and doors remain and the existing hardware is removed and replaced with new?
4. A: Bathroom frames are to remain. All bathroom doors in all sleeping rooms are to be replaced. Door 136D, 138D, 236D, 238D, 336D, and 238D are typical for each sleeping room on each floor. Field verify all dimensions - bathroom doors are 2'-0" x 6'-8" Steel, Type "F"

Hardware:

1 ½ pair	Hinges	A5112
1	Lockset	F76
1	Overhead Stop	C25041
3	Silencers	As specified