

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0014		3. EFFECTIVE DATE 02/16/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 06-0054	
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-06-R-0054
				X	9B. DATED (SEE ITEM 11) 01/26/10
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

06-0054, Interior/Exterior Repairs to BEQ HP445

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Q: Keyed note 1, sheet A-101 requires a solid surface vanity top with porcelain drop-in bowl. Past renovations have used a 1 piece solid surface sink top with integral bowl. Which is required?

1. A: Provide porcelain drop in bowl in solid surface vanity.

2. Q: On sheet F-101 Life Safety Plan it has a statement that the "Existing Building is fully sprinklered with a NFPA 13R System". This proposes two questions 1) why does the FX-101 fire protection site plan show a new run-in for a new sprinkler system and 2) why does the FX-102 & FX-105 show design criteria and notes for a new system if the building is already protected? Is the statement on F-101 meaning that the system needs to be provided with a new NFPA-13R system not already existing.

2. A: This is a misprint on building 445's F-101 sheet. There is not an existing sprinkler system installed currently at this building. The new system shall be installed per the sprinkler plans.

3. Q: The drawings and specs call for a wet system for the existing barracks to be designed to NFPA 13 standards using 0.10 density over the most remote 3000 sq. ft. All other BEQ's are rated and designed at NFPA 13R standards for the barracks. This will eliminate the need to protect closets and bathrooms that will more than double the required sprinklers heads. SFP has sprinkled several recent BEQ's in the last two years and have always used NFPA 13R requirements for the design criteria which is acceptable and approvable by the UFC 3-600-1 and NFPA 13 standards. By which standard are we to design, NFPA 13 or NFPA 13R?

3. A: Provide an NFPA 13 system.