

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0008		3. EFFECTIVE DATE 02/11/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 06-0054	
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-06-R-0054
				X	9B. DATED (SEE ITEM 11) 01/26/10
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

06-0054, Interior/Exterior Repairs to BEQ HP445

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Q: Sheet A-101, demo note #18 says "Remove existing gypsum board ciling and metal framing to permit installation of new mechanical equipment." Sheet A-104 shows framing for new entire soffit. Are we to remove entire soffit to include framing?

1. A: Yes, remove entire soffit and soffit framing.

2. Q: Previous BEQ renovation required shower drains to be back outlet. Specs and drawings do not clarify if back outlet shower drains are required. Will back shower drains be required for this project?

2. A: Yes, back outlet shower drains are required.

3. Q: The following doors are shown as demoed with frames to remain, but in the door schedule it shows the openings to have new frames. Please confirm which is correct, door schedule or demo plan: 140A, 140B, 140C, and 144A.

3. A: Door 140A, 140B, 140C, and 144A on 4/A-101 should have demo note 10 (doors and frames are to be removed and replaced).

4. Q: Door 401A is shown in the door schedule as 3'0" x 6'8", but on sheet A-105 it is shown as 3'0" x 7'0". Which is correct?

4. A: Note 2 on A-105 should read 3'0" x 6'8"

5. Q: There are 2 ext. doors at Mech. 1 through 6 that do not appear to be included in the door schedule, but appeared to be demolished on the demo floor plan. Do they get demoed? If so please assign these doors door numbers and hardware sets.

5. A: Mechanical rooms doors and frames are in good condition and are to remain.