

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0004		3. EFFECTIVE DATE 01/22/08	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 06-0050	
6. ISSUED BY Resident Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521		CODE ase	7. ADMINISTERED BY (If other than Item 6) See Item 6		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-06-R-0050
				x	9B. DATED (SEE ITEM 11) 12/14/07
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

06-0050, Major Interior/Exterior Repairs, BEQ HP-215

1. Amendment 0003 was inadvertently posted without page 2 of 2. This amendment incorporates the information that was omitted from Amendment 0003.

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	
15C. DATE SIGNED		16C. DATE SIGNED	

CONTINUATION SHEET

2. Question: Is it the intent of this project to replace ALL existing receptacles, GFI's etc as part of this work? If it is, I will need to go and do a count of at least one of the rooms and of the main areas. The legends do not even show a symbol for receptacles or GFI's so it is a little confusing as to what the intent is.
2. Answer: All existing receptacle circuits shall remain. Remove 400 existing duplex receptacles and cover plates. Provide 400 duplex receptacles and cover plates. Remove 100 existing GFI duplex receptacles and cover plates. Provide 100 duplex receptacles and cover plates.

3. Question: E-3 The Attic drawing shows Heat Detectors in the Attic. In the previous projects these detectors were deleted from the project. None of the barracks have Heat Detectors in the Attic according to Simplex and JCI. Please verify this requirement and request.
3. Answer: Sheet E3 delete requirement for heat detectors in attic.

4. Question: On sheet M-1. Note 4 states to "remove existing exhaust fans and ductwork to exhaust riser." On sheet A-9, detail 8 shows us reinforcing openings in the floor and roof. If the existing exhaust ductwork is to be reused then are we required to add this reinforcement to existing penetrations or only new penetrations?
4. Answer: Sheet A-9, detail 8 Add note: This detail only applies to new penetrations.