

N40085-32-R-7522

**NAVFAC SPECIFICATION
32-7522**

AMENDMENT NO. 0004

IMPORTANT

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.

If your proposal has been submitted prior to the receipt of this amendment, acknowledgment should be made, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgment must be received prior to the due date established for the receipt of proposals.

| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | 1. CONTRACT ID CODE J | PAGE OF PAGES 1 4 |
|--|----------------------------------|--|---|-------------------------------|
| 2. AMENDMENT/MODIFICATION NO. 0002 | 3. EFFECTIVE DATE 05-Mar-2010 | 4. REQUISITION/PURCHASE REQ. NO. ACQR1140331 | | 5. PROJECT NO.(If applicable) |
| 6. ISSUED BY NAVFAC MID ATLANTIC NORTH CAROLINA IPT 6506 HAMPTON BLVD NORFOLK VA 23508-1212 | CODE N40085 | 7. ADMINISTERED BY (If other than item 6) See Item 6 | | |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code) | | X | 9A. AMENDMENT OF SOLICITATION NO. N40085-10-R-5300 | |
| | | X | 9B. DATED (SEE ITEM 11) 11-Feb-2010 | |
| | | | 10A. MOD. OF CONTRACT/ORDER NO. | |
| | | | 10B. DATED (SEE ITEM 13) | |
| CODE | FACILITY CODE | | | |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS | | | | |
| <input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. | | | | |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required) | | | | |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14. | | | | |
| A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. | | | | |
| B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B). | | | | |
| C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: | | | | |
| D. OTHER (Specify type of modification and authority) | | | | |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office. | | | | |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) P031 MULT-PURPOSE MACHINE GUN RANGE The purpose of this amendment is to adjust corporate experience, respond to RFIs and extend proposal due date. RECEIPT OF PROPOSALS IS CHANGED FROM MARCH 12, 2010 TO APRIL 2, 2010 @2:00PM ALL REQUESTS FOR INFORMATION (RFIs) SHALL BE SUBMITTED NO LATER THAN 10 CALENDAR DAYS PRIOR TO RECEIPT OF PROPOSALS. SUBMIT RFIs TO MICHAEL BRICE VIA E-MAIL @ MICHAEL.BRICE@NAVY.MIL | | | | |
| Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect. | | | | |
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | | |
| | | TEL: | EMAIL: | |
| 15B. CONTRACTOR/OFFEROR | 15C. DATE SIGNED | 16B. UNITED STATES OF AMERICA | | 16C. DATE SIGNED |
| _____ (Signature of person authorized to sign) | | BY _____ (Signature of Contracting Officer) | | 05-Mar-2010 |

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION 00010 - SOLICITATION CONTRACT FORM

The following have been added by full text:

AMENDMENT 0002

PAGE 48

CHANGE:

FROM:

2) **Technical Factors**

a.) **Factor 1, Corporate Experience:**

(1) Solicitation Submittal Requirements: Submit a maximum of three (3) projects similar in size, scope and complexity to the RFP, unless Offeror is a Joint Venture. If the Offeror is a Joint Venture/Teaming arrangement, a minimum of 2 projects per partner must be submitted. The projects should be completed by your firm within the past five (5) years. Use the attached Corporate Experience Form (Attachment A) to submit projects. Project description for each project shall explain the detailed scope of work performed and the relevancy to the project requirements of this RFP. Include in each project description any official LEED Certifications received from the U.S. Green Building Council (USGBC) for that project (if any).

(2) Basis of Evaluation: The basis of evaluation will include experience of the Offeror with projects involving 1) earthwork, upgrading roadways and site development efforts of greater than 50-acre sites; 2) electrical and communication cable installation of greater than 50,000 meters; 3) the ability to work on separate and multiple sites concurrently; and, 4) CMU and steel structures. Single projects must be over \$18 million in magnitude AND achieve at least THREE of the other experience factors listed above to be considered similar to the complexity of the project shown in the RFP

TO:

2) **Technical Factors**

b.) **Factor 1, Corporate Experience:**

(1) Solicitation Submittal Requirements: Submit a maximum of three (3) projects similar in size, scope and complexity to the RFP. The projects should be completed by your firm within the past five (5) years. Use the attached Corporate Experience Form (Attachment A) to submit projects. Project description for each project shall explain the detailed

scope of work performed and the relevancy to the project requirements of this RFP. Include in each project description any official LEED Certifications received from the U.S. Green Building Council (USGBC) for that project (if any).

(2) Basis of Evaluation: The basis of evaluation will include experience of the Offeror with projects involving 1) earthwork, upgrading roadways and site development efforts of greater than 50-acre sites; 2) electrical and communication cable installation of greater than 50,000 meters; 3) the ability to work on separate and multiple sites concurrently; and, 4) CMU and steel structures. Single projects must be over **\$12 million** in magnitude AND achieve at least **THREE** of the other experience factors listed above to be considered similar to the complexity of the project shown in the RFP

NCIPT RFI # 13

1. Option #6 on page 5 of 60, calls for the price of work associated with the ETC berms, please confirm that these are the ETA berms noted on the drawings.

Response: Option #6 was modified via amendment #1. This amendment provides details regarding ETA berm options.

2. Options #4 & 5 on page 4 of 60, calls for the price of the work associated with ETC east and ETC west respectively, Please confirm that the work is shown on the following (unless covered in another option):

- a. ETC east includes drawings C161-C166
- b. ETC west includes drawings C151-C160

Response: Options #4&5 have been modified via amendment #1. This amendment provides details regarding options.

3. Drawing P-101 describes the location of the domestic water stub-out but C-125 and C-126 do not show a tap into the new 300mm water main, note#8. Please confirm that the Government will provide the water supply to the Combined Facility up to 5' outside the building boundary.

Response: Potable water service lines will be provided by others as indicated on the drawings. Stubouts are provided for future connection by others in the event that the service lines do not exist (i.e., have not been installed) at the site at the time of construction.

NCIPT RFI # 16

Drawing E-194 Ammunition Bunker does not show any interior electrical systems. The notes reference STD 421-80-06 which also does not show any interior electrical. Are there no lights or electrical systems associated with the interior of this structure?

Response: Lighting and electrical systems are not indicated to be provided/installed inside the Ammunition Bunker (ECM) storage area. Ammunition Bunker (ECM) Electrical lighting, power, and communications systems (along with electrical rough-in) are required to be provided as indicated. (Electrical Rough-In through the Ammunition Bunker (ECM) storage area wall for the Intrusion Detection System (IDS) is required to be provided/installed as indicated; however, the IDS system is provided/installed by others.)

NCIPT RFI # 19

In order for us to provide the Government with the best and most accurate bid proposal, CADD files will be required in order for us to calculate our earthwork quantities. Can CADD files be made available for this project?

Response: No, those files are not available (They will be made available to the awardee).

(End of Summary of Changes)