

**NAVFAC
SPECIFICATION**

**4831292, Replace
Wastewater Pump Station,
B-3956**

AMENDMENT NO. 0003

IMPORTANT

This amendment should be acknowledged when your bid is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the bid.

If your bid has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your sealed bid is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to bid opening time.

| | | | | |
|---|--|---------------------|------|----------|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | 1. CONTRACT ID CODE | PAGE | OF PAGES |
| | | | 1 | 1 |

| | | | |
|---------------------------------------|--------------------------------|----------------------------------|--------------------------------|
| 2. AMENDMENT/MODIFICATION NO. 0003 | 3. EFFECTIVE DATE 8/19/2009 | 4. REQUISITION/PURCHASE REQ. NO. | 5. PROJECT NO. (If applicable) |
|---------------------------------------|--------------------------------|----------------------------------|--------------------------------|

| | | | |
|--|-------------|--|------|
| 6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533 | Code N40085 | 7. ADMINISTERED BY (If other than item 6.) | Code |
|--|-------------|--|------|

| | | |
|--|-------------------------------------|--|
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR BID | <input checked="" type="checkbox"/> | 9A. AMENDMENT OF SOLICITATION 4831292 |
| | | 9B. DATED (SEE ITEM 11) 6/8/2009 |
| | <input type="checkbox"/> | 10A. MODIFICATION OF CONTRACT/ORDER NO. |
| | | 10B. DATED (SEE ITEM 13) |
| CODE FACILITY | CODE | |

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers is extended is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

4831292, REPLACE WASTEWATER PUMP STATION, B-3956, MARINE CORPS AIR STATION, CHERRY POINT, NORTH CAROLINA

This amendment is issued to provide the following information on the basic RFP:

See Continuation Page

| | | | |
|---|------------------|--|------------------|
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | |
| 15B. CONTRACTOR/OFFEROR (Same as Item 8) | 15C. DATE SIGNED | 16B. UNITED STATES OF AMERICA BY | 16C. DATE SIGNED |
| (Signature of person authorized to sign) | | (Signature of Contracting Officer) | |

Amendment Information Sheet

SECTION 01 19 00, DESIGN SCOPE OF WORK

PART 1 GENERAL

1.6.1 Existing Ratings

Add to this paragraph:

“For Pump Station #3956

The intent is to provide a duplex pump station. Each pump shall meet two different duty points on a single pump curve.

The design point that is to be utilized in defining the capacity of the existing pump station is that each pump shall be capable of 300 gpm @ 120' TDH.

The pumps shall have a high head shutoff of 142’.”

SECTION 02 00 00, CONSTRUCTION SCOPE OF WORK

PART 1 GENERAL

1.3 New Replacement Pump Stations

1.3.5 Construction Work for each pump station

g.

Revise this subparagraph to read in its entirety as follows:

“Provide a screening system on the influent pipe in wet well. New screen system shall be approved by the Contracting Officer. Provide an outside lifting hoist to enable base maintenance personnel to remove and replace the screening system for periodic cleaning. The intent is to provide a manual influent screen or trash basket similar to those produced by Halliday products.”

End of amendment