

**NAVFAC  
SPECIFICATION**

**4831292, Replace  
Wastewater Pump Station,  
B-3956**

**AMENDMENT NO. 0004**

## **IMPORTANT**

**This amendment should be acknowledged when your bid is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the bid.**

**If your bid has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your sealed bid is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to bid opening time.**

2. AMENDMENT/MODIFICATION NO. 0004 8/25/2009	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
---	-------------------	----------------------------------	--------------------------------

6. ISSUED BY <b>CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533</b>	Code N40085	7. ADMINISTERED BY (If other than item 6.)	Code
--	-------------	--	------

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)  <p style="text-align:center"><b>AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR BID</b></p>	<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION 4831292		
	<input type="checkbox"/>	9B. DATED (SEE ITEM 11) 6/8/2009  10A. MODIFICATION OF CONTRACT/ORDER NO.  10B. DATED (SEE ITEM 13)		
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">CODE FACILITY</td> <td style="width:50%;">CODE</td> </tr> </table>	CODE FACILITY	CODE		
CODE FACILITY	CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers  is extended  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
  - B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
  - C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
  - D. OTHER: (specify type of modification and authority)
- E. IMPORTANT: Contractor  is not  is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

4831292, REPLACE WASTEWATER PUMP STATION, B-3956, MARINE CORPS AIR STATION, CHERRY POINT, NORTH CAROLINA

This amendment is issued to provide the following information on the basic RFP:

See Continuation Page

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR (Same as Item 8)  _____ (Signature of person authorized to sign)	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)
15C. DATE SIGNED	16C. DATE SIGNED

Amendment Information Sheet  
Amendment 0004

SECTION 02 00 00, CONSTRUCTION SCOPE OF WORK

PART 1 GENERAL

1.3 New Replacement Pump Stations

1.3.5 Construction Work for each pump station

e.

At the end of this subparagraph, add:

**“NOTE THAT THE EXISTING PUMP STATION HAS AN EXISTING SCADA SYSTEM. The existing system is a Johnson Controls system that is approximately 5 years old. There are approximately 32 pump stations at Cherry Point with the same identical designed Johnson Control SCADA as found at this existing pump station. Bidders should contact Johnson Controls to understand the details of the existing system. There are Johnson Control drawings that provide design details of the existing system. The new pump station will have the same type of system as the existing. It may be possible to reuse the existing system components and connectivity for the new pump station. It is likely that the monitoring points in the existing SCADA database at Building 87 will be completely reusable without adjustment. The telephone number for Johnson Controls in Wilmington, NC is 910-799-2400, FAX number 910-799-2405.”**

End of amendment